

GRESHAM-BARLOW SCHOOL DISTRICT JT10

FCC Form 470# 260014874

Vendor Q and A

1. Which unit needs the (10) UPS - Lithium External Battery Pack? That model works with either the 1500kva/2000kva below. We have a different EBM for each UPS.
 - a. A model that would work with both 1500 or 2000 UPSes is preferred. SKUs for external battery packs/modules of both levels should be included in the quote if there is not a universal model.
2. UPS - Power Distribution + Automatic Transfer Switch – there are a few options listed for this ATS (1.4kW (120V) or 2.4kW (208V) or 2.3kW (230V)). Do we know which one they need?
 - a. The power transfer switch (VA4U11A0) accepts any of the listed voltages, and the max wattage is listed by voltage. This is a single model.
3. The attachments are not included in the RFP document.
 - a. Please visit https://erate.imesd.k12.or.us/form_470?application_number=260014874 to view and download the attachments listed in the RFP document. Note that there are no attachments for the RFP named “RFP 2026 E-Rate Low Voltage Cabling”. The attachments are only for the RFP named “2026-GRESHAM-BARLOW SD-C2” which is for networking equipment.